



PANASONIC

Panasonic 4472 end-of-line device, 1 pc

Product code 41277 · Fire alarm systems > Field devices > I/O units

Panasonic 4472 end-of-line device for use with alarm devices. Sales unit 1 pc.

- Installed after the last device on a supervised alarm device line
- Short-circuit and open-circuit supervision of the line in accordance with EN 54-13

Technical data

Product code	41277
Manufacturer	Panasonic
Product group	Fire alarm systems > Field devices > I/O units

Documents

The manufacturer's original documents can be downloaded from the product page (QR code at the top of this sheet).

Technical datasheet (series): EBL512 G3 5000 and 5001

Request a quote or ask for more information

Sales +358 40 668 7641 · myynti@pap.fi · Mon–Fri 8 am – 4 pm (Finnish time)

Up-to-date information and documents: pap.fi/en/tuote/panasonic-4472-paatelaite-1-kpl/