

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction products

Fire detection and fire alarm systems – Part 4: Power supply equipment

for fire safety use in fire detection and fire alarm systems for buildings, with specification and performance as specified on page 2 in this certificate.

Product name: EBLOne, EBLOne with key, hifire 4100 XS

placed on the market under the name or trademark of

Panasonic Fire & Security Europe AB

Jungmansgatan 12
SE-211 11 Malmö, Sweden

and produced in the manufacturing plant

Scanfil Malmö AB, Bronsyxegatan 6, SE-213 75 Malmö, Sweden

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standards

EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002 and EN 54-4:1997/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 2023-06-22 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Issued by notified body 0402.

The validity of this certificate can be verified at RISE homepage.



Stefan Coric
Director Product Certification

Certificate 0402-CPR-C500348 | issue 1 | 2023-06-22

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-50115 Borås, Sweden

+46 10 516 50 00 | certifiering@ri.se | www.ri.se

1139788

This document is the property of RISE and may not be reproduced other than in full, except with the prior written approval by RISE

Specification

EBLOne, EBLOne with key and hifire 4100 XS is a microprocessor controlled intelligent fire alarm system, intended for analog addressable detectors, as well as conventional detectors and manual call points.

EBLOne front cover
2010, Main board 9364-3B
Power supply unit MDR-40-24
5088, Gateway Unit FP-14C (Optional)

The different variants of EBLOne is according to below:

Type no.	Article no.	Product name	Comment
2000	2000	EBLOne	The basic version, without lock switch and the keyhole is hidden.
2000	2000K	EBLOne with key	With lock switch.
2000TN	2000TN	Hifire 4100 XS	Special version for the German market.