

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance 2831-CPR-F2749

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Type 2841 Intrinsically Safe Analogue Addressable Category P Heat Detector (For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Panasonic Corporation
1668 Fujikata
Tsu-shi
Mie-ken
514-8555
Japan

and produced in the manufacturing plant(s):

Panasonic Electric Works Electrical Construction
Material Mie Co., Ltd Head Office
1668 Fujikata
Tsu-shi, Mie-ken
514-8555
Japan

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2017 + A1:2018 – Heat detectors – Point heat detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 06 February 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 6 February 2020

Date of Issue: 16 September 2022

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4

Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2749**Type 2841 Intrinsically Safe Analogue Addressable Category P Heat Detector****Bases:**

Type 2843 – Intrinsically Safe Backbox

Notes:

Meets the requirements of EN 54-5 for:

- Category A1
- Category A2S
- Category BS



P Halligan, Certification Engineer,
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 6 February 2020

Date of issue: 16 September 2022

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie