

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

## Fire detection and fire alarm systems – Part 17: Short circuit isolators

for fire safety use in fire detection and fire alarm systems for buildings.  
Microprocessor controlled input-/output device with integrated short-circuit isolator.

### Product name: 230 VAC relay output unit, type 4460

placed on the market under the name or trademark of

**Panasonic Fire & Security Europe AB**

Jungmansgatan 12  
SE-211 11 Malmö, Sweden

and produced in the manufacturing plant

**Scanfil Malmö AB**, Bronsyxegatan 6, SE-213 75 Malmö, Sweden

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standards

**EN 54-17:2005 and EN 54-17:2005/AC:2007**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

### constancy of performance of the construction product.

This certificate was first issued on 2023-02-01 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Issued by notified body 0402

The validity of this certificate can be verified on our website.



Stefan Coric  
Director Product Certification

Certificate 0402-CPR-C500371 | issue 1 | 2023-02-01

**RISE Research Institutes of Sweden AB | Certification**

Box 857, SE-50115 Borås, Sweden

+46 10 516 50 00 | certifiering@ri.se | www.ri.se

1161908

This document is the property of RISE and may not be reproduced other than in full, except with the prior written approval by RISE

**SWEDAC  
ACKREDITERING**  
Accred. no. 1002  
Certification of  
Products  
ISO/IEC 17065